

**ADDENDUM 001  
REQUEST FOR BIDS  
Sidewalk and Curb Construction, Rte Y Barry County  
RFB # D7-09-070**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and <mailto:ws69s@nih.gov> including it with the original bid. The due date for receipt of bids remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Cathy Bay Intermediate Procurement Agent
Bidder/Offeror Signature  <hr/> (Signature of person authorized to sign)	Department of Transportation  <i>Cathy Bay</i> <hr/> (Authorizing Signature)
Date Signed:	Date Signed: <b>7/10/09</b>

**CHANGE:**

**Exhibit A; Summary Sheet  
Sheet 1 of 2**

The two drop inlets shown on the plans shall be 2' X 2' Type D Precast instead of 2' x 4', built according to Missouri Standard Plan 731.10. There shall be 2 curved vane grates instead of 4 built according to Missouri Standard Plan 614.11. The dimensions of the curved vane grate frames shall be 2' X 2' instead of 2' x 4'.

All other bid requirements remain unchanged.